



TEST REPORT

DATE: 10/28/2008

TEST NUMBER: 117689

CLIENT	Allstate™
--------	-----------

TEST METHOD CONDUCTED	ASTM F1861-02 (Dimensional Stability) Specification for Resilient Wall Base
-----------------------	---

DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Allstate Rubber TPR Covebase
COLOR	-----
ROLL	-----
CONSTRUCTION	-----
FIBER	-----
BACKING	-----
REFERENCE	Manufacturer: Stoler Industries, Dalton, Ga

GENERAL PRINCIPLE

This test determines the dimensional properties of the wall base as a result of exposure to elevated temperature over a specified time. Minimum requirements are listed in the test method in Table 1.

TEST RESULTS

DIMENSIONAL STABILITY	RESULTS
Specimen 1	-0.007 Inch (0.06% Loss)
Specimen 2	-0.005 Inch (0.04% Loss)

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.